

2102 MCKEE ROAD

Building Permit Confirmed ☒
Not Required ☐

BUILDING DEPARTMENT

APPLICATION FOR ELECTRICAL PERMIT

Date 8/24/ 1977 Permit No. 55927

The undersigned hereby makes application to the Electrical Inspector of the City of San Jose for a permit to install electrical fixtures and/or wiring as listed on the reverse side.

Exemption from requirement for State of California for Contractor's License is hereby claimed
by undersigned: as owner ☐ statement filed ☐

Undersigned attests that his State of California Contractor's License # C10 282-475 is in full force and effect and properly authorizes this application.

San Jose City Business License # 48-02347

I certify that in the performance of the work for which this permit is issued I shall not employ any person in any manner so as to violate the workmen's compensation laws of California.

OWNER Taco Charley Restaurant

ADDRESS 2102 McKee Rd San Jose

USE OF BUILDING Restaurant

FIRM Marby Electric, Inc. SIGNED Robert R. Spencer Est.
280-201n

2102 MCKEE ROAD

MARBY

7A

ITEMIZE THE FOLLOWING

120/208, 3 ϕ 4W

New Old

Outlets <u>35</u>	Panels, Cabinets <u>2</u>	Size Service Conduit <u>4"</u>	
Switches <u>20</u>	Switchboards <u>2</u>	Size Service Wires <u>Per P.E.</u>	
Receptacles <u>20</u>	Panelboards	Size Service Switch <u>400A</u>	
Fixtures <u>48</u>	Festoon Lamps	Size Sub Feed Conduit <u>1.5"</u>	
Mercury Lamps <u>4</u>	Dryers	Size Sub Feed Wires <u>1/0</u>	
Ranges <u>2</u> KW <u>7</u>	Heaters	Number of Circuits <u>47</u>	
Signs	Transformers	Number of Motors <u>1</u>	
HP <u>6</u> <u>1/2</u> h.p. <u>1-2</u> h.p.	Phase <u>3ϕ</u>	Ampere Loads <u>73</u>	Lighting <u>280</u> Power <u>280</u>
Miscellaneous			

Rough Inspection 10-18-77 By OKFinal Inspection 11-30-77 By OK

Remarks: 8-26-77 PVC under slab OK. 9-16-77 PVC to plaster areas OK. 10-13-77 EMT on top of roof OK. 10-18-77 No service equip. installed - grand. 280-201n electrode = 2nd node - OK. 11-23-77 SEIN - OK. 11-30-77 Outside chain hung further replaced with PAR 30 type